

2011 WATER QUALITY REPORT FOR Coon Rapids Municipal Utilities

This report contains important information regarding the water quality in our water system. The source of our water is groundwater. Our groundwater is drawn from the Pleistocene aquifer.

Our water quality testing shows the following results:

CONTAMINANT	MCLG	MCL	DETECTED LEVEL	DATE SAMPLED	RANGE OF DETECTION	VIOLATION	SOURCE
Lead (ppb)	0	AL=15	3 1 sample exceeded the AL	July, 2009	0-17	NO	Corrosion of household plumbing systems; erosion of natural deposits
Chlorine (ppm)	MRDLG =4.0	MRDL=4.0	2.42	RAA 2011	1.50-3.01	NO	Water additive used to control microbes
Copper (ppm)	1.3	AL=1.3	0.95	July, 2009	0.358-1.01	NO	Corrosion of household plumbing systems; Erosion of natural deposits
Arsenic (ppb)	0	10	<2.0	October, 4 2011	N/A	NO	Erosion of natural deposits.
Fluoride (ppm)	4	4	1.4	April,5 2011	1.0-1.4	NO	Erosion of natural deposits.
Nitrate [as N] (ppm)	10	10	0.6	April,5 2011	N/A	NO	Runoff from fertilizer use; Erosion of natural deposits.
Sodium (ppm)	N/A	N/A	9.7	April,5 2011	N/A	NO	Erosion of natural deposits.
TTHM (ppb) [Total trihalomethanes]	N/A	80	3.39	July, 2010	N/A	NO	By-products of drinking water disinfection.
Haloacetic Acids (HAA5) (ppb)	N/A	60	<5.00	July, 2010	N/A	NO	By-products of drinking water disinfection.

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L – picocuries per liter
- N/A – Not applicable
- ND -- Not detected
- RAA – Running Annual Average
- IDSE – Initial Distribution System Evaluation
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Coon Rapids Municipal Utilities is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

CONTAMINANT VIOLATIONS

Coon Rapids Municipal Utilities had no violations in 2011.

ADDITIONAL HEALTH INFORMATION

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).

OTHER VIOLATIONS

Coon Rapids Municipal Utilities had no other violations in 2011.

SOURCE WATER ASSESSMENT INFORMATION

The Coon Rapids Municipal Utilities water supply obtains its water from the Pleistocene aquifer. The Pleistocene aquifer was determined to be slightly susceptible to contamination because the characteristics of the aquifer and overlying materials limit the rate at which contaminants can move through the aquifer. The wells will be somewhat susceptible to activities such as farming and raising livestock. A detailed evaluation of your source water was completed by the IDNR, and is available at the Coon Rapids Municipal Utilities Office.

CONTACT INFORMATION

For questions regarding this information, please contact Jon K. Esdohr at 712-999-2225, Monday through Friday during the following hours: 7:00A.M. to Noon or 1:00 to 4:00 P.M.

Decisions regarding the water system are made at the Board of Trustees meetings generally held on the third Thursday of each month at 7:00 A.M. at the Municipal Building and are open to the public.